

TEMPERATURE CONTROLS PTY LTD

ACN: 075 298 592 ABN: 76 075 298 592

7 YAMMA STREET

SEFTON, NSW 2162 AUSTRALIA

PH: (02) 9721 8644 FAX: (02) 9738 9339 EMAIL: sales@temperature.com.au



THERMOCOUPLES * RTD SENSORS * THERMOWELLS * EXTENSION CABLES * LEVEL SWITCHES

Saved: 1028

TEST DATA REPORT (TRANSMITTERS)

ABB
Order No. 5233049

Test Equipment	Serial #	Cal. Date	Due. Date	Test Transmitter	
		/ /	/ /	Serial# 03114	
GLA Calibrator	206629	04/08/2006	04/08/2008		
		/ /	/ /	Tag #	
		/ /	/ /	Tech	PL Date 9.11.06

Sensor Input			Range	
3 wire PT100 RTD				
Input %	Temperature	Actual Output – mA	Calculated Output - mA	
(0)	-50 °C	4.003mA	mA	
	Ω	mA		
25)	-25 °C	8.004mA	mA	
	Ω	mA		
(50)	0 °C	12.001mA	mA	
	Ω	mA		
(75)	25 °C	15.998mA	mA	
	Ω	mA		
(100)	50 °C	9.997mA	mA	
	Ω	mA		

Burnout	<input checked="" type="checkbox"/>	Upscale	<input type="checkbox"/>	Downscale
Zero Adjustability	<input checked="" type="checkbox"/>	Accept	<input type="checkbox"/>	Reject
Span Adjustability	<input checked="" type="checkbox"/>	Accept	<input type="checkbox"/>	Reject
Line voltage effect	%1%	<input type="checkbox"/>	<input type="checkbox"/>	Accept Reject N/A

Other tests: (Describe below)

Tested by

Date Tested

9/11/06

Phillip Lonsdale

MELBOURNE OFFICE: PHONE (03) 9384 0444 FAX: (03) 9384 0204
PROUDLY MANUFACTURING IN AUSTRALIA