



Specify	Quality assurances Documentation	Certificate Reference
	Material certificate – barstock	ORIGINAL
	Hydrostatic Pressure test certificate - Internal	1044
	NACE - Heat treatment certificate	1045
	<i>Cleaned for oxygen IEC 60877 Sealed in plastic bag</i>	1055
	Thermowell calculation to ASME PTC 19.3	1135
	Tagging	STAMP
	ITP (specify)	1056 C
	Other	Specify

TAPERED STEM THERMOWELL RING TYPE JOINT (RTJ) FLANGE

TEMPERATURE CONTROLS PTY LTD Certificate No: QEC 14412
AS/NZS 9001:2000

CONDITIONS

THIS DRAWING IS OUR EXCLUSIVE PROPERTY AND MUST NOT BE COPIED OR HANDED TO ANY OTHER PARTIES WITH OUT WRITTEN PERMISSION. IT SHALL BE RETURNED UPON REQUEST

SYDNEY : 7 YAMMA ST SEFTON , NSW 2162
PHONE : (02) 9721 8644 FAX : (02) 9738 9339
MELBOURNE : UNIT 8 / 280 WHITEHALL ST
YARRAVILLE VIC 3013
PHONE : (03) 9687 0000 FAX : (03) 9687 1900
EMAIL : sales@temperature.com.au



TITLE

SIZE : A4	DATE : 28/10/08	DWG NO : SD 033
SCALE : NTS	DRAWING BY SB	REV : 01