



Specify	Quality assurances Documentation	Certificate Reference
	Material certificate – barstock	ORIGINAL
	Hydrostatic Pressure test certificate - Internal	1044
	NACE - Heat treatment certificate	1045
	<i>Cleaned for oxygen IEC 60877 Sealed in plastic bag</i>	<i>1055</i>
	Thermowell calculation to ASME PTC 19.3	1135
	Tagging	STAMP
	ITP (specify)	1056 C
	Other	Specify

WELD-IN TAPERED THERMOWELL

Instrument Connection	D2	D1	F	U
1/2"NPT or BSP	38.1mm	19mm	45mm	Specify
1/2"NPT or BSP	28.5mm	14mm	45mm	Specify

TEMPERATURE CONTROLS PTY LTD		Certificate No: QEC 14412 ISO 9001:2008
<p>CONDITIONS</p> <p>THIS DRAWING IS OUR EXCLUSIVE PROPERTY AND MUST NOT BE COPIED OR HANDED TO ANY OTHER PARTIES WITH OUT WRITTEN PERMISSION. IT SHALL BE RETURNED UPON REQUEST</p>	<p>SYDNEY : 7 YAMMA ST SEFTON , NSW 2162 PHONE : (02) 9721 8644 FAX : (02) 9738 9339 MELBOURNE : 8/280 Whitehall St Yarraville VIC 3013 PHONE : (03) 9687 0000 FAX : (03) 9687 1900 EMAIL : sales@temperature.com.au</p>	
	<p>TITLE</p>	
	<p>SIZE : A4</p>	<p>DATE : 25/02/10</p>
<p>SCALE : NTS</p>	<p>DRAWING BY R.B</p>	<p>REV : 05</p>

